



Certificate of Compliance

Certificate: 2007286 (LR 65287)

Master Contract: 157731

Project: 2189805

Date Issued: June 23, 2010

Issued to: I-Gard Corporation

7615 Kimbel St, Unit 1
Mississauga, ON L5S 1A8
Canada
Attention: Lucas Deby

The products listed below are eligible to bear the CSA Mark shown



Issued by: R. Tateishi, P. Eng.

Authorized by: Nick Alfano, Operations Manager

PRODUCTS

CLASS 4812 02 - GROUND FAULT DEVICES - Signal Type Detectors

Ground-fault indicator, Model Stop-Lite and VIA, rated input 120-600V ac, 3-ph, 4VA at 120V ac, 100VA at 600V ac; rated relay output 5A, 250V ac; 5A, 30V dc.

Remote Display, Model VIA-R, for use with ground-fault indicator, Model VIA.

APPLICABLE REQUIREMENTS

CSA Standard C22. No. 14 - Industrial Control Equipment

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters