



Certificate of Compliance

Certificate: 1608273 (LR 65287)

Master Contract: 157731

Project: 2483142

Date Issued: December 12, 2011

Issued to: **I-Gard Corporation**
7615 Kimbel St, Unit 1
Mississauga, ON L5S 1A8
Canada
Attention: Sergio Panetta

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 4812 02 - GROUND FAULT DEVICES - Signal Type Detectors

DSP ground alarm trip relay system, open type, consisting of:

DSP-DPS power supply module, rated input 100-240V 50/60Hz, 25VA; outputs +5V, +12V, -12V, 22W max; alarm contacts rated 8A, 240V ac resistive.

DSP-DFM Feeder Module, trip contacts rated 10A, 240V ac resistive.

DSP-DSM system module.

DSP-DM display module.

APPLICABLE REQUIREMENTS

CSA Standard C22. No. 14 - Industrial Control Equipment

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters