



Certificate of Compliance

Certificate: 1801746 (LR 65287)

Master Contract: 157731

Project: 2525129

Date Issued: August 22, 2012

Issued to: I-Gard Corporation
7615 Kimbel St, Unit 1
Mississauga, ON L5S 1A8
Canada
Attention: Sergio Panetta

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 4812 02 - GROUND FAULT DEVICES - Signal Type Detectors

Combination neutral grounding resistor monitor and ground fault relay, Type SIGMA MONITOR, rated input 60-240V ac/dc, 5VA; rated output 8A, 240V ac; 8A, 30V dc, ¼ hp, 240V ac for use with Type NGRS-6, NGRS-10-INCO and NGRS-25 sensing resistors and T3B-INCO current sensor.

Notes:

This equipment is intended for equipment protection only.

APPLICABLE REQUIREMENTS

CSA Standard C22. No. 14 - Industrial Control Equipment

CSA Standard C22.2 No. 144 - Ground Fault Circuit Interrupters