



Certificate of Compliance

Certificate: Master Contract: 157731
Project: 2438624 **Date Issued:** September 2, 2011
Issued to: I-Gard Corporation
7615 Kimbel St, Unit 1
Mississauga, ON L5S 1A8
Canada
Attention: Sergio Panetta

The products listed below are eligible to bear the CSA Mark shown



Richard MacKenzie
Issued by: Richard MacKenzie, P. Eng.

PRODUCTS

CLASS 4812 09 - GROUND FAULT DEVICES - Neutral Ground Impedance Assemblies

Class 4812 09 GROUND FAULT DEVICES – Neutral Ground Impedance Assemblies

Type NGR series, neutral ground resistor assemblies, rated 8.25 kV; 500A max, 10 second Duty; Monitor/
Ground fault Detector rated: 120 Vac; General Purpose (indoor) Enclosure.

APPLICABLE REQUIREMENTS

Technical Information Letter D-31 - Interim Certification requirements for neutral grounding resistor
Assemblies