



Unparalleled Protection

High Resistance Grounding Data Requisition Sheet

Customer Name _____ Project Name _____ Date _____

Standard HRG Requirements

System Type: Wye Delta

System Voltage: 480V 600V 2400V 4160V Other _____

Ground Fault Current: 5A 10A

Pulsing Circuit: 2.5A-5A 5A-10A

Certification: CSA UL OSHPD Seismic Rated

Enclosure Type: OEM Kit NEMA 1 NEMA 3 NEMA 3R

Standard Options: Test Resistor Heater Horn Other _____

Portable Detector Length: 24" 48"

Control Power: Customer Supplied 120VAC (standard) Other _____

Factory Authorized Start-Up and Commissioning:

Advanced HRG Functionality

Switchgear Configuration: Single Main M-T-M

Fail Safe Grounding Circuit Resistor Monitoring Relay Data Logging

Feeder Monitoring and Control: # of Critical Feeders _____

Current Sensor Sizes / Quantity: Torodial 2" ___ 3" ___ 6" ___ 9" ___

Rectangular 4x17 ___ 7x13 ___ 7x26 ___

Communication: Modbus (standard) Other _____

Arc Flash Protection: Pressure Sensor Quantity _____

Optical Point Sensors Quantity _____

