



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1751141 (LR 65287)

Master Contract: 157731

Project: 1981576

Date Issued: 2007/12/03

Issued to: I-Gard Corporation
7615 Kimbel St, Unit 1
Mississauga, ON L5S 1A8
Canada
Attention: Lucas Deby

The products listed below are eligible to bear the CSA Mark shown



Issued by: R. Tateishi, P. Eng.

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 4812 02 - GROUND FAULT DEVICES - Signal Type Detectors

Ground-fault, ground-check monitor, Model GCHK-100, rated input 100-240V ac/dc, 5VA; rated output 10A, 240V ac; 10A, 30V dc, ¼ hp, 240V ac.

Smart remote indicator, Model GCHK-SRI.

System monitor, Model mGARD-SYM, rated input 60-240V ac/dc, 5VA ac or 5W dc.

LED based remote indicator, Model GCHK-DRI.

Ground check zener terminator, Model GCHK-ZT.



Certificate: 1751141 (LR 65287)

Master Contract: 157731

Project: 1981576

Date Issued: 2007/12/03

Note: This equipment is intended for equipment protection only.

APPLICABLE REQUIREMENTS

CSA Standard C22. No. 14 - Industrial Control Equipment

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters